

# ECO-MIX TM

# INSTALLATION, ADJUSTMENT, SERVICE MODEL 269-LF, 369-LF THERMOSTATIC / POINT OF USE MIXING VALVES

269-LF (1/2" NPT)
ASSE 1069 CERTIFIED

369-LF (3/4" NPT)
ASSE 1069 CERTIFIED

These products are certified to meet Low Lead requirements of wetted surface area containing less than 0.25% lead by weight





# **269-LF & 369-LF WARNING:**

When using flex hoses be careful, swivel connectors may damage inlet checks and / or element on outlet on 269-LF and 369-LF models. Coupling fittings may be needed if swivel connectors have a brass protruding tube or any protrusion that may damage the valve.

- Valve should be installed where it can be easily cleaned, adjusted or repaired.
- Inlets are furnished with NPT connections. When soldering close to this unit, DO NOT OVERHEAT, internal components may become damaged.
- 3. Leonard recommends that unions and shutoffs are installed on the inlets and outlet.
- 4. Use solder or pipe cement sparingly. Supply pipes should be flushed before the valve is connected. Flush outlet pipe and valve as soon as it is connected.



### **WARNING!!**



# WATER TEMPERATURES IN EXCESS OF 110°F (43°C) MAY CAUSE SCALDING, SEVERE INJURY, OR DEATH!!

Maximum Operating Pressure: 125 PSI (860 KPA)


**IMPORTANT!** These thermostatic water mixing valves can be adjusted to deliver water at temperatures exceeding 110°F (43°C). After installation, the installer must check the outlet water temperature and adjust the temperature setting to ensure delivery of a safe water temperature not exceeding 110°F (43°C). See "Temperature Adjustment" next page.

1360 Elmwood Avenue, Cranston, RI 02910 USA Phone: 401.461.1200 Fax: 401.941.5310 Email: info@leonardvalve.com

Web Site: http://www.leonardvalve.com

## ADJUSTMENT AND SERVICE

#### TEMPERATURE ADJUSTMENT



- 1. Open hot and cold water supply valves to mixing valve.
- 2. Open mixed water outlet.
- 3. With the fixture in the full open position, calibrate the mixed water outlet temperature by placing a thermometer in the mixed water stream. Loosen knob set screw with 5/64" allen wrench. Adjust the setting of the valve to obtain the desired temperature (counterclockwise, to increase temperature-clockwise to decrease temperature.)
- 4. Tighten knob set screw to lock temperature setting.



### **WARNING**



WARNING! This thermostatic mixing valve's temperature setting MUST be checked. If the temperature is too high (above 110°F, 43°C), the temperature knob must be adjusted immediately. Excessively hot water is DANGEROUS AND MAY CAUSE SCALDING!!

#### PRESSURE-TEMPERATURE:

- ■Minimum Flow: 1.0 GPM (3.8 l/Min)
- Maximum Pressure: 125 PSI (8.6 BAR)
- Maximum Hot Water temperature: 200°F- (93°C)
- Approach Temperature 5°F (2.8°C) above set point.

# TROUBLESHOOTING INSTRUCTIONS

GASKET KIT	Leaking water under knob.  Leaking water between valve cover and body.	GASKET KIT Model 269-LF Model 369-LF 1/WX 1/WX
REBUILDING KIT	Valve will not control temperature after cleaning.	REBUILDING KITModel 269-LFR/269Model 369-LFR/269
CHECKSTOP KIT	Hot water by-pass into cold line. Cold water by-pass into hot line.	CHECK KIT         Model 269-LF       4/220         Model 369-LF       4/320

# SEE PAGE 3 FOR COMPLETE PARTS BREAKDOWN SEE PAGE 4 FOR PIPING IN RECIRCULATED OR NON-RECIRCULATED WATER SYSTEMS


MODEL	IN OUT		MINIMUM FLOW GPM	PRESSURE DROP										
		OUT		5	10	15	20	25	30	35	40	45	50	PSI
			L/MIN	0.3	0.7	1.0	1.4	1.7	2.1	2.4	2.8	3.1	3.4	BAR
269-LF	1/2"	1/2"	1.0	3.5	5.3	6.3	7.0	7.8	8.5	9.3	10.0	10.8	11.5	GPM
	(12.7mm)	(12.7mm)	3.8	13.2	20.1	23.8	26.5	29.5	32.2	35.2	37.9	40.9	43.5	L/MIN
369-LF	3/4"	3/4"	1.0	4.0	5.8	6.8	7.5	8.3	9.0	9.8	10.5	11.3	12.0	GPM
	(19.1mm)	(19.1mm)	3.8	15.1	21.0	25.7	28.4	31.4	34.1	37.1	39.7	42.8	45.4	L/MIN

IMPORTANT!! THIS IS A CONTROL SYSTEM WHICH MUST BE CLEANED AND MAINTAINED ON A REGULAR BASIS (SEE MAINTENANCE GUIDE AND RECORD MGR-1001).

1360 Elmwood Avenue, Cranston, RI 02910 USA Phone: 401.461.1200 Fax: 401.941.5310

Email: <a href="mailto:info@leonardvalve.com">info@leonardvalve.com</a>
WEB: <a href="mailto:http://www.leonardvalve.com">http://www.leonardvalve.com</a>

### VALVE PARTS LIST



### **MODEL 269-LF, 369-LF**

#### **MODEL 269-LF**

#### 1/WX Gasket Kit

Shuttle O-ring

Stem assembly O-ring

Cover O-ring

#### R/269 Complete Rebuild Kit

Return spring

Shuttle assembly

Shuttle O-ring

Stem assembly O-ring

Cover O-ring

#### 4/220 Check valve Kit

2 Check valves

2 Check clips

#### MODEL 369-LF

#### 1/WX Gasket Kit

Shuttle O-ring

Stem assembly O-ring

Cover O-ring

#### R/269 Complete Rebuild Kit

Return spring

Shuttle assembly

Shuttle O-ring

Stem assembly O-ring

Cover O-ring

#### 4/320 Check valve Kit

2 Check valves

2 Check clips

### DISMANTLING & CLEANING

- outlet port.
- 2. Loosen lock screw on side of knob with 5/64" allen wrench.
- 3. Remove the knob screw on top of knob.
- 4. Remove temperature adjustment knob.
- 5. Remove valve cover, which includes the stem assembly.
- 6. The shuttle assembly can now be removed, cleaned and 2. inspected. Be sure to check the condition of the shuttle o-ring and replace if necessary.
- 7. Lubricate the shuttle o-ring before installing the shuttle assembly.
- 8. Install the cover assembly including o-ring back onto valve 3. Hot water bypass into cold line, order checkstop kit and replace and tighten.
- 9. Replace knob and knob screw.
- 10. Valve temperature must be reset after any repairs or cleaning!! See Page 2. Temperature Adjustment

### TROUBLESHOOTING


- 1. Shut off hot and cold water to the valve as well as the valve 1. Leaking water under knob, order gasket kit, replace stem assembly o-ring. Remove knob screw and knob, remove retaining clip, thread out the stem assembly and replace o-ring. Lubricate o-ring, thread stem into cover, replace retaining ring, knob and screw. Valve temperature must be reset after any repairs or cleaning!! See page 2.
  - Leaking water between cover and body, order gasket kit, replace cover o-ring. Remove knob screw and knob and remove valve cover and replace o-ring. Replace valve cover, knob and knob screw. Valve temperature must be reset after any repairs or cleaning!! See page 2.
  - checks within inlets of valve.
  - 4. Valve not controlling temperature even after cleaning, order complete rebuild kit. Remove knob screw and knob and remove valve cover. Replace shuttle assembly and return spring being sure to lubricate shuttle o-ring. Replace valve cover, knob and knob screw. Valve temperature must be reset after any repairs or cleaning!! See page 2.

1360 Elmwood Avenue, Cranston, RI 02910 USA

Phone: 401.461.1200 Fax: 401.941.5310 Email: info@leonardvalve.com


WEB: http://www.leonardvalve.com

# INSTALLATON WITHOUT CIRCULATED TEMPERED WATER



- Model 269-LF and 369-LF Thermostatic Mixing Valves must be installed according to Piping Diagram W if recirculation of tempered water is required.
- 2. Model 269-LF and 369-LF Thermostatic Mixing Valves should be installed below the hot water tank. If the valve cannot be located is this area, the hot water inlet piping to the mixing valve should be installed with a heat trap.

### INSTALLATION WITH CIRCULATED TEMPERED WATER



#### LIMITED WARRANTY

Leonard Valve Company warrants the original purchaser that products manufactured by them (not by others) will be free from defects in materials and workmanship under normal conditions of use, when properly installed and maintained in accordance with Leonard Valve Company's instructions, for a period of one year from date of shipment. During this period the Leonard Valve Company will at its option repair or replace any product, or part thereof, which shall be returned, freight prepaid, to the Leonard factory and determined by Leonard to be defective in materials or workmanship. There are no warranties, express or implied, which extend beyond the description contained herein. There are no implied warranties of merchantability or of fitness for a particular purpose. In no event will Leonard be liable for labor or incidental or consequential damages. Any alteration or improper installation or use of the product will void this limited warranty.

1360 Elmwood Avenue, Cranston, RI 02910 USA Phone: 401.461.1200 Fax: 401.941.5310 Email: info@leonardvalve.com

WEB: http://www.leonardvalve.com